

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7210-1297:103 Page 1 of 1

CATEGORY: Flame Detector

LISTEE: Fire Sentry Corp., 593 Apollo Street, Brea, CA 92621
Contact: *David Daniels (714) 671-1100 FAX (714) 671-5821

DESIGN: Model FS7 System 7 consisting of Model FS7-2173, S7-2173C, FS7-2173-RP, FS7-2173-2RP flame detectors, FS7-130-SX, S7-2175, FSWB controllers, S7-2177-1 and S7-2177-2 battery panel, S7-2178 power module and Model FS7-2179 (JB-4) junction box. Suitable for indoor use only. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 20 – 26 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number and FM label.

APPROVAL: Listed as flame detector system for use with separately listed compatible fire alarm control units.

*Rev. 06-16-2003



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 22, 2004

*Listing Expires **June 30, 2005***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager